



Central Valley Water  
Reclamation  
Facility

**CENTRAL VALLEY LOCAL LIMITS**  
**Adopted April 2022**

<b>Pollutant of Concern</b>	<b>Local Limit</b>
Arsenic, mg/L	1.2 (m)
Cadmium, mg/L	0.1 (m)
Chromium (Total), mg/L	5 (m)
Copper, mg/L	3.6 (m)
Lead, mg/L	1.9 (m)
Mercury, mg/L	0.006 (m)
Molybdenum, mg/L	7.9 (m)
Nickel, mg/L	5.2 (m)
Selenium, mg/L	0.4 (m)
Silver, mg/L	5 (d)
Zinc, mg/L	12.1 (m)
Cyanide, mg/L	1.2 (m)
Petroleum-based Oil and Grease, mg/L	100 (d)
pH, s.u.	5-12 (i)

(m) = monthly limit, (d) = daily limit, (i) = instantaneous limit